



Notes:

1. ACKNOWLEDGE push button is lighted with red lamp that remains on as long as voltage is applied.
2. Buzzer sounds when voltage is first applied and is silenced by pushing the ACKNOWLEDGE push button.
3. Normally open contacts are typically provided from TraceTek monitor panels such as TTA, TTB, TTC, TTE, TTG or TTM.

©1994 Raychem Corporation

TTE-XAL External Alarm Unit

TRACETEK

Industrial Division of Raychem Corporation

CAD FILE NAME: TTE-XAL.DWG	DWG N3	BY: KN EL-020	DATE: 06/16/94
-------------------------------	-----------	------------------	----------------